



MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE

(A Grant-in-aid autonomous institute under R.G.P.V., Bhopal, M.P.)

Ph: +91-751-2409300, Fax: +91-751-2664684, e-mail: infomitsgwl@gmail.com, Website: www.mitsgwl.ac.in

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Civil/ AT/DR/ No 1383

Date: 30/05/2017

It is certified that I have visited the Morning Star School, Mau Road, Badagaon, Morar, Gwalior on 28.05.2017 in the presence of Principal Ms. RANI PRAVAL for inspecting the safe drinking water and sanitary condition in the School. There are 12 toilets, 12 urinals and 24 drinking water taps in all. Everything is found in order and in good condition. I have found that the Morning Star School, Mau Road, Badagaon, Morar, Gwalior has safe drinking water facilities for the students and member of the staff of the Institute and is maintaining the hygienic sanitation condition in the School Building and the campus/premises as per the guidelines prescribed by the Education Department of the State/ C.B.S.E.Board.

The above is valid for a period of one year.

Signature with stamp of Prof. Deepak Rastogi
M.E. 'CIVIL', LMISTE, F.I.E.
Associate Professor, Civil Engg. Deptt.
M.I.T.S., Gwalior
Name - Prof. D. Rastogi
Designation- Associate Professor

To,
Morning Star School,
Mau Road, Badagaon, Morar,
Gwalior-474006
Madhya Pradesh

Ramavtar

सचिव


शिक्षा विभा प्रसार एवं समाज सेवा सचिव,
बढ़ागाँव रोड, मॉर्निंग स्टार स्कूल, गढ़ने के पास
पुतर, ग्वालियर (M.P.)

PRINCIPAL
Morning Star School
Mau Road, Badagaon
Morar, Gwalior-6 (M.P.)



MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE

(A Grant - in - aid autonomous institute under R.G.P.W. Gwalior, M.P.)



+91-751-2409300, Fax: +91-751-2664684, Email: infomitsgwl@gmail.com, Website: www.mitsgwl.ac.in

Ref: CIVIL/ 453 /AT/DR/ Env.Engg. Lab/TR- 144 /No. Tc4340/1437 Date: 02/06/17

To,
The Principal
Morning Star School,
Mau Road, Badagaon, Morar,
GWALIOR - 474006 (M.P.)



Ref.: Your Letter No. Nil Dated 27.05.2017
Sub: Testing of Water Sample used for drinking purpose.

Dear Sir,
Please find herewith the testing report of the water sample sent by you vide above mentioned reference and subject.

TESTING REPORT

| S.No. | Parameters/Tests | Laboratory Results |
|---------------------------------|------------------|------------------------------|
| (A) Physical Tests | | |
| 1 | Temperature | 30.4°C |
| 2 | Turbidity | Nil |
| 3 | Colour | Absent |
| 4 | Odour/Taste | Un - objectionable |
| (B) Chemical Tests | | |
| 5 | pH Value | 8.40 |
| 6 | Acidity | 06 mg/l as CaCO ₃ |
| 7 | Alkalinity | 84 mg/l as CaCO ₃ |
| 8 | Total Solids | 48 mg/l |
| 9 | Dissolved Solids | 48 mg/l |
| 10 | Suspended Solids | Nil |
| 11 | Chlorides (Cr) | 18 mg/l |
| 12 | Hardness | 38 mg/l as CaCO ₃ |
| 13 | D.O. | 6.1 mg/l |
| (C) Bacteriological Test | | |
| 14 | MPN/ 100ml | Nil |

- Remarks:
- Testing charges of Rs. 2890/- deposited vide challan No. 1094 U.B.I.M.I.T.S. Branch Gwalior dated 30-05-2017.
 - The above tested parameter of water sample complies with the drinking water standard laid down in IS: 10500-1991. Hence water sample is found fit for drinking use.
 - The above results are only for the information to the referred agency. The institute does not take any responsibility of the use of this result for any other purpose, legal or otherwise.

[Signature]
Faculty

Prof. I/C PHE Lab.
& Testing

सचिव

महिषा शिक्षा इकाय एवं समग्र सेवा समिति,
बझगाँव रोड, मॉर्निंग स्टार स्कूल, हाइवे के पास
मुरार, ग्वालियर (म.प्र.)

[Signature]
H.C.E.D.

Forwarded by

[Signature]
PRINCIPAL

Morning Star School
Mau Road, Badagaon
Morar, Gwalior-6 (M.P.)



MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE

(A Grant - in - aid autonomous institute under R.G.P.V., Bhopal, M.P.)

Race Course Road, Gwalior (M.P.)

Ph.: +91-751-2409300, Fax : +91-751-2664684, e-mail : infomitsgwl@gmail.com, Website : www.mitsgwl.ac.in

FIRE SAFETY CERTIFICATE

No. Civil/ AT/DR/ No 1382

Date : 30/05/2017

It is certified that the Morning Star School, Mau Road, Badagaon, Morar, Gwalior (M.P.) comprised School Building ground floor, Computer Center, Library, Staff Rooms, Corridors and three upper floors owned by Morning Star School have complied with the fire prevention and fire safety requirements in accordance with rule of State Govt. Fire Safety Rules, and verified by Prof. Deepak Rastogi, Associate Professor, Civil Engineering Department, M.I.T.S. Gwalior on 28.05.2017 in the presence of Principal MS. RANI PRAVAL and found that the building/ premises is fit for occupancy Class -B (Education building up to Senior Secondary Level) with effect from 30.05.17 for a period of three years in accordance with rule and subject to compliance of the conditions.

Issued on 30.05.2017 at Gwalior by

Signature with seal
Prof. Deepak Rastogi
M.E. 'CIVIL', LMISTE, F.I.E.
Associate Professor, Civil Engg. Deptt.
M.I.T.S., Gwalior

Name - Prof. Deepak Rastogi
Designation- Associate Professor

To,
Morning Star School,
Mau Road, Badagaon, Morar,
Gwalior-474006 (M.P.)

- Conditions for the validity of fire safety certificate :-
- 1) All the means of escape/ entry/ exit shall be kept free from any obstruction.
 - 2) All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
 - 3) All the Staff Members must know the correct method of operation of fire fighting system.
 - 4) Any lapse rendering fire fighting system /equipments non functional shall be risk and responsibilities of the Management of the Institute.

Rama Vala
सचिव

शिक्षा विभा प्रसार एवं सहाय सेवा समिति,
बदगाँव रोड, मॉर्निंग स्टार स्कूल, हस्ती रोड पास,
मुरार, ग्वालियर (म.प्र.)

Principal
Morning Star School
Mau Road, Badagaon
Morar, Gwalior-6 (M.P.)